

VIOLATION AND RECOMMENDATION SCHEDULE

(23 IL Adm. Code 180, Sections 180.320)

1. COUNTY CODE 071, Ogle			2. DISTRICT CODE/NAME 2200, Oregon CUSD 220		3. FACILITY CODE/NAME Oregon Elem School	
4. Item ID	5. Location(s) (Room No)	6. Priority Code	7. Rule Violated	8. Description of the violation	9. Recommendation to correct violation	
1	Main Water Service	a.	Main Water Service Break	The existing domestic water service to the building sprung a leak on the exterior of the building.	See specifications.	

SCHEDULE OF RECOMMENDED WORK ITEMS AND ESTIMATED COSTS

1. COUNTY CODE 071, Ogle			2. DISTRICT CODE/NAME 2200, Oregon CUSD 220				3. FACILITY CODE/NAME Oregon Elem School				
4. Item I.D.	5. Action I.D.	6. Priority Code	7. Specification(s)	8. Units Of Measure	9. Quantity	10. Labor Code	11. Estimated Cost (Architect / Engineer)	12. ROE Adjustment	13. ISBE Adjustment	14. Estimated Completion Date	15. Funding Type
1	c	a.	Emergency Amendment - The water line had to be dug up and repaired.	lump sum	1	2	\$8,317.50			12/13/2021	F

	Original Subtotal	\$8,317.50	Adjusted Subtotal	\$8,317.50	
	Original 0.00% Contingency	\$0.00	Adjusted 0.00% Contingency	\$0.00	
	Original 0.00% A/E Fees	\$0.00	Adjusted 0.00% A/E Fees	\$0.00	
	Original Grand Total	\$8,317.50	Adjusted Grand Total	\$8,317.50	

Items with a Funding Type of 'O' are not included in the cost calculation.
35-48 (7/07) (Prescribed by ISBE for Local Board Use)