

1. COUNTY CODE 071, Ogle				2. DISTRICT CODE/NAME 2200, Oregon CUSD 220				3. FACILITY CODE/NAME OREGON ELEM SCH - ETNYRE WING						
Item I.D.	Location(s) (Room No)	Rule Violated	Description of the violation	Recommendation to correct violation	Action I.D.	Priority Code	Specification(s)	Units Of Measure	Quantity	Labor Code	Estimated Cost	ISBE Adjustment	Estimated Completion Date	Funding Type
1	South portion of Roof	175.210	Existing roof is leaking in locations and repairs need to be made.	See specifications.	c	b.	Repair roof in locations of leaks.	lump sum	1	2	\$2,800.00		9/1/2020	F
2	4 Classrooms	175.210 Tripping Hazard	Existing carpeted flooring is causing a tripping hazard because of its condition. These pictures were taken on days when there was no humidity. When there are humid days, the wrinkles get much worse then what is shown in the photos.	See specification.	e	b.	Remove and replace existing flooring.	sf	4	2	\$26,000.00		9/1/2020	F

Violation / Work Item Listing